

**BID B0821, Fire Sprinkler and Suppression Services
Questions and Answers**

#	Vendor (contact & company)	Subject	Question	Response
1.	David Mulkey – Cliff's Fire Extinguisher		Section 3.14 refers to painted sprinkler heads, will there be any requirements to painters on how their painting process is done or exclusions based on irresponsible painting that covers sprinkler heads?	CCSD will make every effort to prevent any sprinkler heads from being painted. Our in-house painters know not to paint them. Every attempt will be made to hold painting contractors liable for any heads painted.
2.	“		On the cost proposal form there is pricing for fire extinguisher recharges, will we be able to charge for any and all service that comes due to portable fire extinguishers including all recharging?	No. These prices are only if we request a recharge for something that was out of scope (i.e. recharges that are requested by CCSD throughout the year). If an extinguisher is discovered to be low <u>during the vendor's inspection</u> , they must replace/recharge at no additional cost to CCSD.
3.				
4.				
5.				
6.				